

DPW WORK REPORT

January 2022

- **Christmas lights were checked, put up and then taken down. The lawn trailer turned into a sleigh again this year for Santa.**
- **North St lift station electric work is scheduled to be completed on December 13th by CT Electric.**
- **The electric furnace in the #1 well house died. I had Cliff and Sons out to look at replacement. A quote for a replacement was received.**
- **I contacted consumers energy business and submitted a request for construction for 2 street lights at the end of Spires Parkway.**
- **Some snow brought us in to plow and clear downtown.**
- **Brush pickup ongoing now that were past leaves.**
- **The Nitrate experiment I did on the system showed that nitrate levels in well #1 started out at 6.6 mg/L and dropped to 5.7 mg/L in 1 1/2 hours of run time on the pump. The level of nitrates in town was 1.2 mg/l here at the Village Office. Results were sent to the State and I spoke with Katelyn at EGLE about these results.**
- **We had a bubbler compressor quit in the Meadow lift station. I placed an order with Smith and Loveless for a replacement. I rebuild them at long as possible but rebuild kits are 2+ months out and they only had 1 compressor in stock. Usually rebuild kits arrive in a few days but like everything else supplies are limited.**
- **I have several water meters on order. It may be several weeks yet before they show up. We are not in need yet and hopefully residents have protected theirs from freezing.**
- **Meters were read. Discharge was completed and all year end reports submitted to the State.**