

DPW WORK REPORT

Sept. 2021

- **Well #1 update - The State so far has not granted any permits. With Vacations of staff and management at Peerless Midwest Not much has happened this month.**
- **The storm knocked out power for over a week at the water plant. Generator power kept alarms working and we monitored tower levels until power was restored.**
- **Lots of clean up had us busy for the week. The storm happened on a Wednesday and we had all the brush that had been put out picked up by the following Thursday of the next week.**
- **Sidewalks in front of the Village Office and across the street at Allen and Church were pulled for replacement. We were able to have everything opened up by the start of garage sales.**
- **The storm damaged the pump controller at the lift station at the west end of North St. We will be submitting the quote for replacement to the insurance once we get it.**
- **Everything was mowed and made ready for the Labor Day festivities to try and show case our community.**
- **Lots of brush was picked up at the water plant.**
- **The string of aerators just arrived for the lagoons. We will begin assembling these soon.**