

DPW WORK REPORT

- **Trimming of the trees and bushes on a list sent out to homeowners that were not addressed were taken care of along with several others.**
- **Sidewalks on North St. and Church St. were pulled for replacement. These were in bad shape and came up in pieces. We also hauled sand and some top soil for use on the sidewalks.**
- **Water system flushing with chlorine went smoothly. All hydrants are operational and have been pumped down for the winter. The water tower was purposely over flowed to chlorinate as high up on the water tower walls as possible and to clear anything that might be floating on the surface.**
- **Steel was purchased from Phillips steel, painted and installed behind the two electric heaters at the mens restroom.**
- **We blew a tire on the dump box truck. All of them were worn out and as we need this truck to haul the leaf vac and with the heavy loads it takes we had them replaced.**
- **We had 3 high usage water complaints. We met with the residents to find possible solutions.**
- **We served several water shut-offs with one being in-accessible due to a junk pickup truck parked over the curb stop. Gary and the property owner met with the tenants and attempted to shut the water off at the meter. As the attempt was made Gary was bit by the dog there. The shut off was not completed. Arrangements were made by the tenants to bring the past due bill into compliance.**
- **Discharge of the lagoons is on going thru December.**
- **Major clog of flushable wipes in the main lift station was cleared.**
- **Blowers were all serviced at the lagoons.**
- **Leaf pickup has begun.**