

# DPW WORK REPORT

November 2020

- Flushing with chlorine went well. We kept about .4 ppm throughout town. Chlorination began Monday, October 19<sup>th</sup> and stopped on October 22<sup>nd</sup> at the end of the day. We allowed the water tower to go to overflow to get treated water as high on the interior walls as we could and to flush out anything floating in the surface.
- All hydrants worked properly and all have been pumped down for winter. We just need to do a leak back check before we get too cold.
- Discharge continues until December 31<sup>st</sup> at the lagoon ponds.
- The storm drain retrofit device seems to work. We will continue to work on this through the winter.
- Leaf pickup is well underway. To date we have transported 83 loads of leaves out of town.
- The tree cutters continue to work on finishing up. All the trees are down but trunks and stump grinding still needs addressed.
- The water plant is now fully automatic should there be a power failure. We were finally able to find a way to trigger the automatic door opener when the power goes out.
- PFAS testing came back negative for both wells.
- Meter reading was done and all reports sent to the State.